

Request for Proposals

Site: Central Fire Station, N Union St, Olean

Job: Furnishing & installing new fire alarm system (see specs below)

Contact: Dave Kahm, City Electrician, (716) 376-5662 or (716) 378-2827

Proposals Due: May 26, 2010

- ∇ 1ea Simplex 4006-9101 conventional fire alarm panel (or equivalent approved by City Electrician). Fire alarm panel shall be equipped with communicator to be programmed to communicate to City of Olean Dispatch Center
- ∇ 2ea batteries for backup power
- ∇ 3ea manual pull stations
- ∇ 7ea horns/strobes
- ∇ 5ea heat detectors
- ∇ 3ea photo/smoke detectors
- ∇ 8ea detector 2-wire bases
- ∇ 1ea labor to install new wire in existing conduit, install devices, and fire alarm control panel. Start up, full system test, certification, and any programming needed
- ∇ 1ea One year warranty on all parts and labor