

The City of Olean is seeking quotes for the purchase of a fixed gas monitoring system.

Required specifics of unit:

1. Alarm relays for each channel (4).
2. Remote readout, min. 50' distance from sensors
3. 120 VAC power
4. 4-20mA output
5. The following sensors are needed:
 - a. Carbon Monoxide
 - b. Hydrogen Sulfide
 - c. Oxygen
 - d. Chlorine
6. Calibration gas cylinder(s) and associated components for in-house calibration of the unit.

Quoted price shall include all components, wiring, and delivery to our facility. Installation is NOT required. The City of Olean is tax-exempt.

Please contact one of the following persons for more information. **Deadline for quotes is Dec. 1, 2011.**

**Dale Walker or Rich Graves
City of Olean Water Plant
1332 River Street
Olean, NY 14760
716-376-5699
Fax: 716-376-5704**

Company Name: _____

Contact Person: _____

Address: _____

Phone/Fax: _____

QUOTED PRICE: _____

Signed by: _____

Print Name: _____

Title: _____

Quote Valid until: _____